

July 31, 2020

Tuolumne Utilities District

NOTICE TO PLANHOLDERS
ADDENDUM NO.1

PROJECT: Techite Pipeline Replacement Project

TO: All Planholders of Record

FROM: Tuolumne Utilities District

BID DATE: Unchanged

Notice is hereby given to prospective bidders that the Bid Documents for the above referenced project have been modified as hereinafter set forth. This Addendum No.1 shall form a part of the Bid Documents and takes precedence over the original Bid Documents.

The following revisions, additions, or deletions shall be made to the Contract Documents:

REVISION: Sheet C15

The new pipeline connecting the new pressure reducing valve assembly to the existing 8" line shall be 8" C900 rather than 6". The corresponding valve shall also be 8". The pipe shall reduce down to 6" no more than 10' before and after the PRV.

REVISION: Sheet C15 and CDT-2, Detail 3

Contractor shall make the connection between the new 10" C900 and the existing valve assembly using the 8" DIP shown in the detail in Phase 1.


REVISION: Sheet C19

Contractor shall install a fire hydrant assembly at location where a blow off is shown (STA 91+80.98). Exact location to be staked out by TUD Inspector.

ADDITION:

Engineer's Estimate is \$411,000.00

Bidders shall acknowledge receipt of the Addendum No.1 in the space below and include this page with the bid. Bidders shall also acknowledge receipt of this Addendum No.1 by indicating so in the blank space provided in the Bidder's Checklist. Failure to do so may subject bidder to disqualification.



Erik D. Johnson
District Engineer

I acknowledge receipt of the Addendum No.1, consisting of one (1) page.

Signed _____
Bidder