

August 11, 2020

Tuolumne Utilities District

NOTICE TO PLANHOLDERS
ADDENDUM NO.3

PROJECT: Techite Pipeline Replacement Project

TO: All Planholders of Record

FROM: Tuolumne Utilities District

BID DATE: Unchanged

Notice is hereby given to prospective bidders that the Bid Documents for the above referenced project have been modified as hereinafter set forth. This Addendum No.3 shall form a part of the Bid Documents and takes precedence over the original Bid Documents.

The following revisions, additions, or deletions shall be made to the Contract Documents:

REVISION: Section 01010-1.01-b-3

Section 01010-1.01-b-3 is replaced with the following:

Bypass and Tie into Existing Water Main (LS): Furnish and install 8” temporary bypass that allows a new water main to be placed in approximately the same location as the existing main. See Supplementary Condition 43 for length requirements. This item includes payment for required bypass plans, constructing the bypass, flushing, disinfection, removing the bypass, temporary pressure reducing stations, placing and removing temporary customer hookups.

REVISION: Supplementary Conditions

The following is added to Supplementary Condition 43, “Bypass:”

Contractor shall disinfect and flush the temporary bypass in accordance with AWWA standards for drinking water prior to placing it in service. The water in the bypass line must pass a total coliform bacteria test (Bac-T) as well. The Bac-T is performed and paid for by the District. Contractors should be advised that the test can take between 48 and 72 hrs before results are delivered.

Supplementary Condition 57, “Disposal of Existing Techite Water Main” is replaced with the following:

The existing Techite watermain **must** be dug out and disposed of. Techite is not a hazardous material.

Bidders shall acknowledge receipt of the Addendum No.3 in the space below and include this page with the bid. Bidders shall also acknowledge receipt of this Addendum No.3 by indicating so in the blank space provided in the Bidder’s Checklist. Failure to do so may subject bidder to disqualification.



Erik D. Johnson
District Engineer

I acknowledge receipt of the Addendum No.3, consisting of one (1) page.

Signed _____
Bidder