

February 26, 2021

Tuolumne Utilities District

NOTICE TO PLANHOLDERS
ADDENDUM NO.1

PROJECT: Techite Pipeline Replacement Project, Phase II

TO: All Planholders of Record

FROM: Tuolumne Utilities District

BID DATE: Unchanged

Notice is hereby given to prospective bidders that the Bid Documents for the above referenced project have been modified as hereinafter set forth. This Addendum No.1 shall form a part of the Bid Documents and takes precedence over the original Bid Documents.

The following revisions, additions, or deletions shall be made to the Contract Documents:

REVISION: Invitation to Bid

The fifth paragraph of the Invitation to Bid is replaced with the following:

A mandatory pre-bid conference will be held at the High Grade Ln. cul-de-sac (17407 High Grade Ln.), Sonora, California at 9:00 a.m. on **Thursday, March 11, 2021**. Proposals will only be accepted from contractors represented at the pre-bid conference.

ADDITION: Supplementary Conditions

The following is added to the Supplementary Conditions:

69 Minimum Separation Variance – The Contractor may request that the District reduce the minimum required separation between the parallel 12” C900 DR 14 pipes. If the Contractor makes this request, the Contractor shall submit a drawing of the proposed trench cross section for District approval. The Contractor shall not make any change to the planset without written approval from the District. A minimum of 1 foot separation shall be required in any case.

70 Meeting with Private Property Owner – The Contractor’s superintendent and foreman shall meet on site with the District and the property owner of 23050 Middle Camp Road at least 2 weeks prior to performing work within 100’ of the property to discuss the logistics of the work being performed near the property.


ADDITION:

Engineer’s Estimate is \$688,172.00

CLARIFICATION: Planset

The planset incorrectly calls for DR 18 C900 pipe. All C900 installed shall be DR 14.

Bidders shall acknowledge receipt of the Addendum No.1 in the space below and include this page with the bid. Bidders shall also acknowledge receipt of this Addendum No.1 by indicating so in the blank space provided in the Bidder's Checklist. Failure to do so may subject bidder to disqualification.



Erik D. Johnson
District Engineer

I acknowledge receipt of the Addendum No.1, consisting of two (2) pages.

Signed _____
Bidder